



Sea-Bird GmbH

Postfach 1167, 87401 Kempten, Germany

Phone: +49 831 9 60994 701 Fax: +49 831 960994 709

Email: seabird.eu@seabird.com

Temperature Calibration Report

Customer:	CNRS/LOV		
Job Number:	E00145	Date of Report:	3/28/2013
Model Number:	SBE 03Plus	Serial Number:	03P5144

Temperature sensors are normally calibrated 'as received', without adjustments, allowing a determination sensor drift. If the calibration identifies a problem, then a second calibration is performed after work is completed. The 'as received' calibration is not performed if the sensor is damaged or non-functional, or by customer request.

An 'as received' calibration certificate is provided, listing coefficients to convert sensor frequency to temperature. Users must choose whether the 'as received' calibration or the previous calibration better represents the sensor condition during deployment. In SEASOFT enter the chosen coefficients. The coefficient 'offset' allows a small correction for drift between calibrations (consult the SEASOFT manual). Calibration coefficients obtained after a repair apply only to subsequent data.

'AS RECEIVED CALIBRATION'

Performed Not Performed

Date:

Drift since last cal: Degrees Celsius/year

Comments:

'CALIBRATION AFTER REPAIR'

Performed Not Performed

Date:

Drift since 11 May 12 Degrees Celsius/year

Comments: