



Sea-Bird Electronics, Inc.  
13431 NE 20<sup>th</sup> Street  
Bellevue, WA 98005  
USA

Phone: (425) 643-9866  
Fax: (425) 643-9954  
E-mail: seabird@seabird.com  
Web: www.seabird.com

**APPLICATION NOTE NO. 18-4**

**Revised August 1992**

**SBE 18 pH SENSOR CALIBRATION EQUATION ERROR**

The equation used in SEASOFT through 4.007 calculates pH as:

$$\text{pHold} = (\text{pH}_{\text{ref}} + (\text{Vout} - \text{B}) / \text{M}) / (^\circ\text{K} * 1.98416\text{e-}4)$$

where  $^\circ\text{K}$  = temperature in degrees Kelvin

This equation ignores the glass electrode potentials and temperature compensation that are used to create a 0 volt output (independent of temperature) from the pH sensor at pH 7.

The new equation (used in SEASOFT V 4.008 and later) has the form:

$$\text{pH} = 7 + (\text{Vout} - \text{offset}) / (\text{slope} * ^\circ\text{K} * 1.98416\text{e-}4)$$

where slope and offset are computed (PHFIT V 2.0) from a least squares fit of Vout and pH in a series of buffer solutions using the measured temperature of the buffer solutions.

The relationship between the two equations (ignoring the difference between M and slope) is:

$$\text{pH} = \text{pHold} + (7 - \text{pH}_{\text{vref}} / (^\circ\text{K} * 1.98416\text{e-}4)) + ((\text{B} - \text{offset}) / (\text{slope} * ^\circ\text{K} * 1.98416\text{e-}4))$$

where B and  $\text{pH}_{\text{vref}}$  are the calibration coefficients used to compute pHold

and slope is the calibration coefficient computed by PHFIT V 2.0